

SECTION 00 91 13

ADDENDUM NO. 3

APRIL 17, 2024

PROJECT: Window & Door Replacement at
Captains Golf Course
1000 Freemans Way
Brewster, MA

- This addendum forms a part of the Contract Documents and modifies the original Bidding Documents dated March 2024 as noted below.
- Please advise all sub-contractors.
- Acknowledge receipt of this Addendum in the space provided on the Bid Form.

GENERAL

- A. The following are questions submitted by Bidders to the Owner and their subsequent answers are highlighted in red.
1. Question: On the Captains Windows the specifications do not call for impact rated windows however the building code requires it for commercial buildings. Are impacts being required for this project?
Response: Spec Section 08 52 16: Paragraph 1.4.D.2 states “All windows must meet the requirements for Large Missile Impact” and the specified windows are Andersen’s hurricane windows with Stormwatch Protection glass.
 2. Question: The sub bids for the exteriors doors are they using impact glass in their products if it is so required as per questions #1.
Response: Spec Section 08 81 00-Glass & Glazing: Paragraph 2.02 states the Impact Resistant Glass to be used. The schedule at the end of this Spec Section was updated in Addendum No. 1 to state that the Impact Resistant Glass is to be used in the exterior aluminum entrance doors and storefront framing

End of Addendum No. 3